



Municipal Council Tumsar
Dist. Bhandara (Maharashtra)



Phone-STD No.07183-Off.234679

mail : co.mc.tumsar@gmail.com

NPT/F.V./218 /2024-25

Date:22/08/2024

--: FIRE SAFETY CERTIFICATE :--

Certified that Principal of **LOTUS INTERNATIONAL PUBLIC SCHOOL, At-Thana/Kharbi, Tah. Bhandara, Dist. Bhandara** comprised of Ground floor basement(s) and First Floor owned/occupied by Lotus International Public School, At-Thana/Kharbi, run by Shri Dhanlaxmi Bahuddeshiya Sanstha, Bhandara, have completed with the fire prevention and fire safety requirements in rule of Maharashtra Fire Safety Regulation, 2006 and verified by me on Service dt. **16/08/2024** in the presence of **Mr. Ajit Kaur Bhatia**, Principal Lotus International Public School, At-Thana/Kharbi and that the have occupancy up to classes XII with effect from dt. **10/08/2024 to 09/08/2025** in accordance with rule & subject to compliance of specific condition.

- 1) School has instructed to get all the fire safety equipments Inspected in every year i.e. January to December and get Form B from which has to be submitted mandatorily to the Municipal Council, Tumsar.
- 2) According to the Maharashtra Fire Prevention and Lifesaving install fire hydrant and sprinkler with alarm system.
- 3) Fire Extinguishers equipments BC (CO2) of 4.5 kg. Quantity 02 of numbers were installed and these are valid till **09/08/2025**.
- 4) Fire Extinguishers equipments ABC (DCP) of 06 kg. Quantity 08 of numbers were installed and these are valid till **09/08/2025**.
- 5) 4 Fire Bucket with Stand 1 Number and Safety Indication Board were Installed in building premises.
- 6) It is also certified that Fire Extinguishers Equipments are in good conditions to run the School.





(J.N. CHAWARE)

In-charge Fire Officer,
Municipal Council, Tumsar.
Dist. Bhandara.