

FIRE SAFETY CERTIFICATE


Ref. No. SET / CER/3163/2026-27

Dated : 02.09.2026

Certified that the Principal of Lotus International Public School, Thana / Kharbi situated at Bhandara Road Thana / Kharbi . Comprised of Ground + 2Nd floor occupied by Lotus International Public School, Thana / Kharbi, run by Shri Dhanlaxmi Bahuudheshiya Sanstha Bhandara, have completed with the fire prevention and fire safety requirements in accordance with Fire safety rule of Sate / UT fire service Rules, and verified by the officers concerned of 31.08.2026 [date of inspection] in the presence of Principal, Mr. Pannala Puitandi of Lotus International Public School, Thana / Kharbi and that the said school premises is fit for the occupancy up to Classes X. With effect from 31.08.2026 to 30.08.2027 for a period of one year in accordance with rule & subject to compliance of specific conditions as appended :-

- 1] Fire Extinguishers equipment's ABC [DCP] Type of 6 Kg. of 12 number were installed and these are valid till 30.08.2027
- 2] Fire Extinguishers equipment's BC [CO2] Type of 4.5 Kg. of 01 number were installed and these are valid till 30.08.2027
- 3] Fire Exit Signage, Fire Instruction and Emergency Contact Board Have been installed at the school premises
- 4] It is also certified that Fire Extinguishers equipment's Servicing, Refilling, Maintenance are in good conditions to run the School.
- 5] This Certificate is valid for the period upto 30.08.2027 year from the date of issue.

Issued on 02.09.2026 (dated of issue) at Bhandara (place)by



Signature with Seal.....Bumde.....

Name: Apreksha Ghumde

Designation : Project Manager

To,
Principal
Lotus International Public School,
Thana / Kharbi